

From

The Head  
Department of Microbiology  
PAU, Ludhiana.

To

The Principal  
Shri Guru Ram Rai Public School  
Sekhewal road  
Ludhiana

Memo. No. 901

Dated: 28/03/22

Subject: Bacteriological quality of drinking water (IS-10500:1991. BIS New Delhi).

Reference is made to your letter No. nil dated 25.03.2022 regarding sample of water for bacteriological analysis.


### REPORT

S. No.	Source	Coliform organisms		Faecal Coliform / E. coli Detected / Not detected
		Present/ Absent	Most Probable Number index (<10/100ml)	
01	Water sample	Absent	--	Not Detected


### INFERENCE

Bacteriologically safe :- 01

Bacteriologically not safe :- nil

  
Incharge 28.3.2022  
Water Testing Lab  
Department of Microbiology  
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

  
Head  
Department of Microbiology